

J. Basic. Appl. Sci. Res., 2(6)6194-6200, 2012 © 2012, TextRoad Publication ISSN 2090-4304 Journal of Basic and Applied Scientific Research www.textroad.com

Body Immune Algorithm Based Method for Optimal Capacitor Placement in Power Distribution Networks

Majid Davoodi¹, Mohsen Davoudi², AliAref¹ and Iraj Ganjkhany²

¹Department of Electrical Engineering, Takestan Branch, Islamic Azad University, Takestan, Iran. ²Department of Electrical Engineering, Abhar Branch, Islamic Azad University, Abhar, Iran.

ABSTRACT

Optimal placement of capacitors in the power distribution system is an issue that many designers in the distribution system pay attention to it since many years ago and do many studies in this field. Detection of capacitance and optimal placement of capacitors in power distribution system can lead to decrement in losses, enhancement in voltage profile, increment in power factor and freeing up generation capacity and energy distribution. The majority of literatures pay more attention to solve this problem considering only some of the parameters related to the capacitor placement. This paper aim to investigate all most of influencing factors in the capacitor placement as a target function. In this paper to find the optimum location and capacitance of the capacitors, a proposed method based on the Immune algorithm has been employed in simulations. The important advantage of the Immune algorithm rather than the other methods is its performance in multifunction manner that can investigate many parameters in the target function. The proposed capacitor placement and detecting optimum capacitance method has been implemented and tested in a 9-bus IEEE sample network in DIGSILENT and MATLAB environments. **Key words**: Capacitor, Optimal placement, Body immune algorithm.

INTRODUCTION

Most of the electrical apparatuses such as elector motors and transformers are a kind of inductive loads which cause to reduce the network power factor, increase system losses and result in voltage drop on network busses. Power capacitors are such economical devices to provide required reactive power. Installing capacitors between generators and loads can reduce reactive power and result in load reduction and then free up generation capacity. Also this can reduce losses and increase in power factor.

Basically, capacitor installation can increase working capacity of generators and utilities between 30% and 90%. Freeing up the capacity of the generators can let us to employ low power apparatuses and to release us the need for large capacity expansion in far future. But incorrect capacitor placement can run the network to dangerous instability. Therefore the capacitor placement in distribution system by correcting power factor and freeing up the generators capacity from passing reactive current can result in enhancement voltage profile and reduction losses.

In the most of the literatures only some parts of the effective parameters in capacitor placement have been considered. For example in the work presented in[1] only losses reduction and voltage profile enhancement were studied. In [2] to optimize capacitor placement only losses reduction, voltage profile enhancement, freeing up the capacity of the generators and cost of capacitors were taken into account. In [3] only losses reduction, voltage profile enhancement and installation cost of capacitors were investigated. In [4] losses reduction and voltage profile enhancement investigated and in [5] capacitor placement has been done only by considering losses reduction and the installation cost of the capacitors.

This study takes more influencing factors into account in capacitor placement compare to the previous studies. This proposed method for capacitor placement leads to obtain all advantages of the capacitor placement in the power network. Furthermore, a couple of the optimization methods, which have been used in the other works for optimal capacity placement, are presented shortly in the discussion including the comparison with the proposed method.

Problem Statement

The capacitor placement problem is solved optimally considering many factors such as reduction of Ohmic losses, voltage profile enhancement, freeing up the generators capacity, freeing up the distribution capacity, freeing up the distribution utilities starting from gathering voltage and current of all nodes in network by load distribution in DIGSILENT environment. Some candidate buses will be selected then by running immune algorithm in MATLAB

^{*}Corresponding Author: MajidDavoodi, Department of Electrical Engineering, Takestan Branch, Islamic Azad University, Takestan, Iran. E-mail: majid.davoodi@yahoo.com

Davoodi et al.,2012

to detect the optimum place and capacitance of capacitors. The network then is tested by load distribution to check whether the problem requests are metand the indexes are converged. Steps for finding these optimum points are shown in the figure 1.



Figure 1:Optimization steps

Body Immune Algorithm

Immune algorithm is one of the optimization algorithms in the problem solving that inspired from Clonal selection theory in the body immune system. [6]This algorithm is used for optimization with multi function. There are many ways for capacitor placement Such as Numerical programming which is one of the traditional methods to solve capacitor placement in the power distribution system. The current methods are complex and slow in computational point of view. Artificial methods for capacitor placement problem include TABU search, Steel

plating, Particle crow theory, Fuzzy network theory, Artificial networks and Genetic algorithm that can used for capacitor placement problem[7].

This study implements immune algorithm for detection and placement of capacitors considering most of the influencing factors in target function. The proposed method compare to the current intelligent methods such as GA (genetic algorithm) that used in [8] and PSO (particle crowd algorithm) that used in [9], diverges faster.

- Steps of immune algorithm implementation are summarized as follows:
- 1. Coding: is mapping from problem area to search area (creating cells with enough length called anti body).
- 2. Production of initial population: in this stage, anti bodies labeled randomly to create population of zero generation and by load distribution it's appropriation will be judge.
- 3. Affinity: similarity of anti bodies to each other is a parameter called dependency and is given by (1):

$$AFF_{mn}^{a-a} = \frac{1}{1+E(2)}$$
(1)
where *m* and *n* are two distinct anti bodies and AFF is diversity between two anti bodies that is given
by (2)

$$E_j(N) = -\sum_{ij=1}^N P_{ij} \log P_{ij} \tag{2}$$

where P_{ij} is the probability of un-similarity between i^{th} anti body and j^{th} gen with next un-similar cell.

- 4. Selecting anti bodies with high dependency: after calculating dependency level of anti bodies those have high level of dependency will be selected to continue.
- 5. Doing genetic action: on the antibodies with low dependency, genetic actors (e.g. mutation and crossover) imply to increase their level of dependency.
- 6. Clonal stage: in this step anti bodies with high dependency are chosen as the next population in the second generation.
- 7. Controlling stop or continuation condition: in the steps 3 to 7,the number of generations and the best anti bodies that are the answer of the problem are updated until convergence achievement.

The Proposed Method

In this study to compute the capacitance and location of capacitor in the distribution system, the immune algorithm has been used. The target function of the immune algorithm is a cost function that includes most of the known parameters such as cost of decreasing losses, cost of voltage profile enhancement, cost of capacitor installation that include fix and variable cost that is based on capacitor capacitance and has following equation:

$$F_{cost(x)} = K_1 C_l + K_2 C_v + K_3 C_i + K_4 C_f + K_5 C_r \left(\frac{\$}{Kwh}\right)$$
(3)
where:

where:

 $F_{cost(x)}$: target function

- C_l : cost of losses in the network
- C_v : cost of voltage profile enhancement

 C_i : cost of each capacitor installment

 C_f : cost of capacitor (based on it's capacitance)

 C_r : cost of generatorscapacity, lines and distribution utilities development,

 K_1 : coefficient of transferring losses to cost

 K_2 : coefficient of transferring voltage profile enhancement to cost

 K_3 : coefficient of transferring each capacitor installation to cost

 K_4 : coefficient of transferring capacitor capacitance to cost

 K_5 : coefficient of transferring capacity of system an apparatus development to cost

As an example for calculating the cost of losses in the network, the differences of losses in each bus before and after capacitor installation is computed inDIGSILENT. This difference is used as K_1 coefficient multiplied in the voltage profile enhancement cost. The other influencing cost parameters are calculated as like for this one. The K_i are the coefficients of the target function given to DIGSILENTas a matrix called *coefficients matrix*, which is discussed in the next sections. The Limitationsfaced while running the algorithm are as follows:

- 1- Limitation of the buses voltage: $V_{min} < V < V_{max}$, the buses voltage after capacitor installations have not to be more than detected boundaries.
- 2- Limitation of the capacitor bank: used capacitor bank has a fixed capacitance and can't be varied.

In this study a sample network was selected to implement the optimal capacitor placement and capacitance detection by the proposed algorithm considering the most of the known influencing factors.

The Simulated Distribution Network

In this study to compare the results achieved from the capacitor placement in the distribution system a standard 9-bus IEEE power network is selected (its single line diagram is shown in figure 2).



Figure 2: The 9-bus IEEE single line diagram

This network has one voltage source and a data set about its lines and buses shown in tables 1 and 2.

Table1: The 9-bus IEEE network line data set

Sen.bus	Res.bus	X(ohm)	R(ohm)
0	1	0.4127	0.1233
1	2	0.605	0.014
2	3	1.205	0.7463
3	4	0.6084	0.6984
4	5	1.7276	1.9831
5	6	0.7886	0.9053
6	7	1.164	2.0552
7	8	2.716	4.7953
8	9	3.0264	5.3434

Table 2: The 9-bus IEEE network buses data set

No.bus	P(Kw)	Q(Kvar)
1	1840	460
2	980	340
3	1790	446
4	1598	1840
5	1610	600
6	780	110
7	1150	60
8	980	130
9	1640	200

The antibodies (cells) used in the immune algorithm for solving the capacitor placement problem in this study has *n* member. Each member represents one bus in the network. Values of these buses in the *i*th position show the capacitance of the installable capacitors in the *i*th bus. A general form of antibodies is shown in figure 3.

1 2 3 4		n
---------	--	---

Figure 3: A general form of antibodiesused in the immune algorithm

The first generation of the antibodies is initialized randomly in the start of the immune algorithm.

SIMULATION RESULTS

In this study, the optimal placement and capacitance detection of the capacitors using the immune algorithm including the most of the influencing parameters in its target function has been implemented in a 9-bus IEEE network.

Input matrix of target function including coefficients such as cost of losses reduction, voltage profile increment, transferring capacitor installment to cost, transferring capacitor capacitance to cost and transferring over

capacitance of systems and apparatus to cost that called K_1 , K_2 , K_3 , K_4 , K_5 respectively in the target function. The parameters consider environmental, economical conditions such as weather and power market as well (see table 3).

Table 3: destin	nation function coeffic	eients	
	Coefficient	Parameter	Coefficient applied to each parameter in the destination function
	K ₁	Loss reduction	25%
	K ₂	Voltage profile	15%
	K ₃	Capacitor installation cost	25%
	<i>K</i> ₄	Capacitor capacitance cost	20%
	K 5	System over capacitance cost	15%

These coefficients are computed based on their importance and influence on decreasing costs given as a column matrix to DIGSILENT. Notice that these factors may be changed in each network [10].Based on these factors, target function is created and the immune algorithm based optimization method is implemented. The proposed method has been developed in DIGSILEN and MATLAB environments. InMATLAB by assigning values to the algorithm, the results of the standard 9-bus IEEE network are shown in table 4.

Table4: result of running algorithm on a 9-bus IEEE network

Bus	Capacitor size	Number of capacitor	PR
1	KVar300	1	0.89156
3	KVar300	1	
5	KVar600	2	
6	KVar1200	4	

In table4, PR is the index of losses decrement which in the immune algorithm is the ratio of total losses in the system after capacitor placement to all of losses before capacitor placement:

$$PR = \frac{P_{loss} new}{P_{loss}}$$

(4)Where $P_{lossnew}$ and P_{loss} refer to losses after capacitor placement and before it respectively.

Achieved result from losses indexes are as follows:

- PR <1: capacitor placement results in costs reduction.
- PR = 1: capacitor placement does not have any effect on the network costs.
- PR > 1: capacitor placement results in costs increment.

When there is no capacitor placement in the network, the value of the cost function is $F_{cost(x)}$ = 330125 and after capacitor placement based on table $4,F_{\text{cost}(x)}=308705$. In the table 5 detecting the location and capacitance of the capacitors based on the influencing factors using immune algorithm is shown with comparison to the other methods. It can be seen that the results of the proposed method has lower cost than others.

Table 5: comparison proposed capacitor placement with other methods.

Bus	Solution 1	Solution 2	Solution 3	Solution 4	Immune algorithm
1	300	300	300		300
2	300			300	
3		300			300
4				600	
5	300	300	900		600
6	1200	1200	1200	1200	1200
7					
8					
9					
$F_{cost(x)}$	308964	309035	309041	309049	308705

Table 6: Comparing run time of the immune and genetic algorithms

Time of calculation	Number of iterations	Optimization algorithm
5.8 min	300	Genetic algorithm
35 sec	300	Immune algorithm

Davoodi et al.,2012

Table6shows a comparison between immune algorithm and genetic algorithm. In this study we implement capacitor placement and it's capacitance detection for a sample 9-bus standard IEEE network by immune algorithm and genetic algorithm and as shown in table, for equal number of iterations the time of calculations in the proposed immune algorithm is pretty less than genetic algorithm.

DISCUSSION

Optimal placement of capacitor in distribution systems are among the on-going problems that many studies have been done in this area. Due to importance of this problem, different methods are used to find the optimal solution. In this section a couple of optimization methods (Genetic Algorithm and Plant Growth Simulation Algorithm) used in the previous works are shortly described explained:

- 1- Genetic Algorithm (GA) is one of the ways that used for optimal capacitor placement in the power distribution systems. GA worksusinginheritance mechanism, natural evolution and mutation in the gens life. This algorithm start by first population of solutions that are random and achieved the best solution using genetic operators. The solutions of each iterations of algorithm is called Generations. In each Generation the better solutions is replaced with the previous one. A limiting parameter (analogous to the environment in the real life) is controlling the optimization process. In capacitor placement problem a cost function including the optimization parameters, as described in [11] plays the rule of the limiting parameter. Immune algorithm that we used in this paper for optimal capacitor placement is very similar to the GA because it uses mutation and rotation like in the GA. But immune algorithm is able to solve the problem and optimize the solution faster while it can deal with multi target functions as in the proposed method.
- 2- Plant Growth Simulation Algorithm (PGSA) is another method that is used for optimal capacitor allocation. This algorithm is based on the plant growth process, in the way that a plant grows a trunk from its root, then branches will grow from the nodes on this trunk, and then new branches will grow from old branches and this process continue until optimal response be found. In [12] for optimal capacitor placement in distribution system PGSA is used, but target function in the previousworkschecks only two parameters(comprehensive voltage profile and loss reduction)while leaving the other factors.

Conclusion

In this paper the optimal capacitor placement and capacitance detection in power distribution networks using a proposed algorithm based on immune algorithm considering the majority of the influencing factors in its target function have been studied. In the first step, the coefficient of the target function got weighted in a column matrix in which the value of each factor may be different for each network. Entering the factors of the target function in DIGSILENT and running immune algorithm, the results have been achieved. They show that in optimal placement of capacitors and detecting optimum capacitance considering most of the important factors (such as loss reduction, voltage profile enhancement, cost of installation and capacitor cost based on it's capacitance) the best values to target function can be achieved. The advantage of using the immune algorithm is its performance in convergence rate compare to the other methods like genetic algorithm.

REFERENCES

- Baran ME., Wu F.F,1989. Network reconfiguration in distribution systems for loss reduction and load balancing. IEEE Transactions on Power Delivery, Vol. 4, no.2, pp1401, .
- [2] Gallego R.A., MonticelliA.j., Romero R.,2001.Optimal Capacitor Placement in Radial Distribution Networks, IEEE Transactions on Power Systems. Vol. 16, No.4, pp.630-637, .
- [3] D.Das,2008. Optimal Placement of Capacitor in Radial Distribution System Using a Fuzzy-GA Method.Indian Electrical Power and Energy Systems, Vol. 30 pp.361-367.
- [4] F. Mahmoodianfard, H.A. Abyaneh, H. Salehi, A. Vahabzadeh,2011.Optimal capacitor placement for loss reduction, IEEE Transactions on modern electric power systems, pp:1-5.
- [5] T. Ghose, S.K. Goswami, S.K. Basu,1998. Energy loss reduction in distribution system by capacitor placement through combined GA-SA technique. IEEE Transactions on Power Systems, vol.2,pp: 502 – 505.

- [6] Castro, Leandro Nunes de, Timmis, Jonathan, 2002. Artifical Immune System: A New Computation Intelligence Approach. Springer-Verlag pp.357.
- [7] Ng,H.N., Salama, M.M.A., Chikhani, A.Y, 2000. Classification of Capacitor Allocation Techniques. IEEE Transaction on Power Delivery, Vol.15, No 1,.
- [8] M. Delfanti, G.P. Granelli, P. Marannino, 2000. Optimal capacitor placement using deterministic and genetic algorithms. IEEE Transactions on power systems, Vol.15, No.3, pp: 1041 – 1046.
- [9] Xin-mei Yu, Xin-Yin Xiong, Yao-wuWu 2004. A PSO-based approach to optimal capacitor placement with harmonic distortion consideration, *Electric Power Systems Research, Volume 71, Issue 1, Pages 27-33*
- [10] Ali aref, Mohsendavoudi, Majiddavoodi, 20012. Optimal Placement and estimation of DG capacity in Distribution Network's Using Genetic Algorithm-based Method. Indian Journal of science and Technology, Issue 3, Vol 5.
- [11] Gary Boone, Hsiao-Dong Chiang, 1993. Optimal capacitor placement in distribution systems by genetic algorithm. Electrical power and energy, Vol. 15, Issue 3, pp:155 – 161.
- [12] R. SrinivasasRao, S.V.L. Narasimham, M. Ramalingaraju, 2011. Optimal capacitor placement in a radial distribution system using plant growth simulation algorithm. Elsevier, Electrical power and energy systems, Vol. 33, Issue 5, pp:1133 – 1139.
- [13] Yann-Chang Huang, Hong-Tzer Yang, Ching-lien Huang, 1996. Solving the Capacitor Placement Problem in a Radial Distribution Systems Using Tabu Search Approach. *IEEE Transactions on Power Systems*, Vol. 11, No. 4, pp.1868-1873.
- [14] S. Sundhararajan, A.Pahwa, 1994. Optimal Selection of Capacitors for Radial Distribution Systems Using a Genetic Algorithm. *IEEE Transactions on Power Systems*, Vol. 9, No. 3, pp. 1499-1505.
- [15] L. N. De Castro, F. J.VonZuben, 2001. Learning and Optimization Using the Clonal Selection Principle, IEEE Transactions on Evolutionary Computation, Vol. 6, Issue 3, pp: 239 – 251.
- [16] J.D. Farmer, S.A. Kauffman, N.H. Packard, A.S. Perelson,1987. Adaptive Dynamic networks as Models for the immune System and Autocatalytic Sets, *AnnAls of the New York Academy of Science*, Voi. 504, pp: 118-131, 1987.
- [17] D. Dasgupta, 1998. Artificial Immune Systems and their Applications, Springer-Verlag,.
- [18] L.N. De Castro, J. Timmis, 2002. An Artificial Immune Network for Multimodal Function Optimization, *Proc.* of *IEEE Congress on Evolutionary Computation*, Vol.1, pp. 699-704.
- [19] Z.Q. Wu, K.L. Lo, 1995.Optimal Choice of Fixed and Switched Capacitors in Radial Distribution With Distorted Substation Voltage, IEEE Proceedings. Part C, Vol.142, No. 1, pp.24-28.